IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Larry Jenkins DATE 4-23-74 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hwy 21 S. T.R. on Rd. 1336 at Barium Springs. T.R. on Old Mountain Rd. T.R. on Rd 1328, Enoms Rd. T.R. into Parkwood Estates S. R. No. _____

SUBDIVISION NAME Parkwood Acres LOT NO. 5 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes (✓) No ( )

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area 22,500 Sq. Ft.


Character & Porosity of Soil Red Clay

Percolation Rate 70 Min Test

Topography Level

Depth to Water Table Low

Rock or other impervious formations None



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 750 Linear Ft. 300

Depth of Stone in Lines _____

Water Supply: Individual (✓)

Public ( )

Installed by Herman Gibson

IMPROVEMENTS PERMIT BY E. A. Stevenson

COMMENTS: _____

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 4-23-74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold