Flake Pratt
Builder

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Jack White DATE 10-3-74 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hwy 21 S. To Fairground-T.R. on Old Mountain Rd T.L. on E. Monbo Rd # 1328. House in Corner at Parkwood Acres S. R. No. 1328

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes ( ) No (✓)
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Lot Area 31000 Sq ft.

Character & Porosity of Soil Red Clay
Percolation Rate No Perk Test
Topography Slope to Front
Depth to Water Table Low
Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Robert Hoke
R. E. Fox

IMPROVEMENTS PERMIT BY _____

COMMENTS: Original layout changed due to location of well being changed.

CERTIFICATE OF COMPLETION BY E. G. Stevenson DATE 10-3-74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold