Larry Jenkins
Belk.

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Robert Purcell DATE 5-19-75 PERMIT NO. _____

PHONE: Business _____ Home _____


LOCATION Parkwood Acres,
1st House on R. S. R. No. _____

SUBDIVISION NAME Parkwood Acres LOT NO. 21 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2
Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )
Lot Area 125 X 180

Character & Porosity of Soil Red Clay
Percolation Rate Good
Topography Low
Depth to Water Table None
Rock or other impervious formations _____



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )
[redacted]

Installed by Robert Hoke
R. E. Foy

IMPROVEMENTS PERMIT BY _____

COMMENTS: Water from Downspouts should be diverted away from lines. [redacted]

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 5-19-75

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold