IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Gene Russell DATE 8-22-74 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hwy 115 S. To Troutman - T.R. on Talley St. Trailer behind Lilli Mae Lucky Home. Across Street from Poker Lounge S. R. No. 1324


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 5 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Unk
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	No Perk Test
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Slight Slope
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	Low
			Rock or other impervious formations	None

Lot Area 25,624
+ Easement on Property adjoining



Plot of System

Size of Tank 1500 Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. 1250 Linear Ft. 500
Depth of Stone in Lines 10"
Water Supply: Individual ( )
Public (✓)

Installed by Mercer & Grant

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 8-22-74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold