4731881815

DENR/DEH

ON-SITE WASTEWATER SECTION

Sheet 1 of 1
PROPERTY ID #: 17544G
COUNTY: Iredell

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: CeO Properties
APPLICATION DATE 4-8-13
ADDRESS: 117 Sheriff's Ct
DATE EVALUATED: 4-16-13
PROPOSED FACILITY: 3BR
PROPOSED DESIGN FLOW (.1949): 240
PROPERTY SIZE: .46
LOCATION OF SITE: 117 S. Sheriffs Ct.
PROPERTY RECORDED: yes
WATER SUPPLY: • Private • X Public • Well • Spring • Other
EVALUATION METHOD: • X Auger Boring • Pit • Cut
TYPE OF WASTEWATER: • X Sewage • Industrial Process • Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	10% LS	0-14	CL / SBK	ss sp	Chr. 4 @ 39"	48	n/a	n/a	.3 PS
		14-48	C / SBK	ss sp					
2	10% LS	0-14	CL / SBK	ss sp	Chr. 4 @ 42	46	n/a	n/a	.3 PS
		14-46	C / SBK	ss sp					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	III	III
Site LTAR	.25	.25

OTHER FACTORS (.1946): none
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: James Stewart
OTHER(S) PRESENT: Chad Overcash

COMMENTS: