DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

4731913732 PROPERTY ID #: _____ Sheet ___ of ___
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Amy Money
ADDRESS: 216 Kendall Rd Hartman NC 28106
PROPOSED FACILITY: House PROPOSED DESIGN FLOW (.1949): 360
LOCATION OF SITE: Perth (Hartman) (L) ERA (R) Lake Circle
APPLICATION DATE 5-24-05
DATE EVALUATED: 2-14-05
PROPERTY SIZE: .769 AC
PROPERTY RECORDED: Aug 80

WATER SUPPLY: ☐ Private ☐ Public ☑ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	4%	0-12	SCL WSBK	SS SP Sexpfr		48			.4 RS
		12-30	CL WSBK	SS SP Sexpfr					
		30-48	CL MSBK	SS SP Sexpfr					
2	6% L	0-7	SCL WSBK	SS SP Sexpfr		48			.4 RS
		7-32	CL WSBK	SS SP Sexpfr					
		32-48	CL MSBK	SS SP Sexpfr					
3	6%	0-9	SCL WSBK	SS SP Sexpfr		48			.48 RS
		9-36	CL WSBK	SS SP Sexpfr					
		36-48	CL MSBK	SS SP Sexpfr					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	900/300	900/300
System Type(s)	Conv./Gravel.	25% Rep
Site LTAR	.4	.4

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): RS
EVALUATED BY: _____
OTHER(S) PRESENT: Kelly Orr

COMMENTS: _____