DEPARTMENT OF ENVIRONMENT, HEALTH & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

DRAFT

PROPERTY I.D.#: _____
DATE: _____
COUNTY: _____

SOIL SITE EVALUATION FOR ON-SITE WASTEWATER SYSTEM

APPLICANT: Elizabeth Lawrance OWNER__ AGENT__ PHONE: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED 1-24-95
PROPOSED FACILITY: _____
PROPERTY SIZE: _____
LOCATION OF SITE: _____
WATER SUPPLY: On-site Well____ Comm. Well____ Public____ Other_____ EVAL. METHOD: Auger Boring ✓ Pit___ Cut___

PROFILE #	.1940 LANDSCP POS./ SLOPE(%)	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY	MATRIX COLOR	MOTTLE COLOR	OTHER PROFILE FACTORS
1	2-3%	0-8"	sl	gr	1:1			.1942 Wetness Cond. -
	R	8"-40"	c	sbk	1:1			.1943 Depth/.1956 Sapr. -
		40"-48"	c/sap.	wsbk/m	1:1			.1944 Restrictive Hori. -
								.1948 Profile Class. -
								Profile LTAR .3
2	2-3%	0-10"	sl	gr	1:1			.1942 Wetness Cond. -
	R	10"-30"	c	sbk	mixed 5, 5P		relic mottling	.1943 Depth/.1956 Sapr. -
		30"-42"	c/sap.	wsbk/m	mixed. 5, 5P		relic mottling	.1944 Restrictive Hori. -
		42"-48"	sap.	m				.1948 Profile Class. -
								Profile LTAR .25
3	2-3%	0-8"	sl	gr	1:1			.1942 Wetness Cond. -
	R	8"-20"	c	sbk	1:1			.1943 Depth/.1956 Sapr. -
		20"-28"	c/weathered Rock	wsbk/m	1:1			.1944 Restrictive Hori. -
		28"-37"	c	wSbk	1:1			.1948 Profile Class. -
		37"-48"	c/sap.	wsbk/m	1:1			Profile LTAR .35
4	2-3%	0-8"	sl	gr	1:1			.1942 Wetness Cond. -
	R	8"-48"	c	Abk/m	1:1/2:1	mixed 5, 5P	relic mottling	.1943 Depth/.1956 Sapr. -
								.1944 Restrictive Hori. -
1-25-95								.1948 Profile Class. -
								Profile LTAR .25

AVAILABLE SPACE (.1945)_____ OTHER FACTORS (.1946)_____ SITECLASSIFICATION (.1948)_____

SYSTEM TYPE_____ LONG-TERM ACCEPTANCE RATE(S)_____

EVALUATED BY:_____ OTHER(S) PRESENT:_____

COMMENTS:_____