IREDELL COUNTY HEALTH DEPARTMENT

County Building — Phone 1164 — Statesville, N. C.

PERMIT TO INSTALL SEPTIC TANK

Permit No. 644 Permit Date 7-2-47 194___

Owner J. M. Wiseman Address Troutman

Tenant ___ Address ___

Installed by Sam Oswalt Address Troutman

Location of property Wagner St. Troutman N.C.

Kind of tank Concrete Capacity 800 Length of trench 120 + 20


NOTIFY HEALTH DEPARTMENT AT LEAST EIGHT HOURS BEFORE TANK IS TO BE INSPECTED

There must be at least 200 feet of tile in line, with cinder pit at end.

Final Inspection 7-2-47 194___ Approved (✓) Disapproved ( )

Remarks: Ok P

First five feet of line from outlet should be of cast iron soil pipe.



L E Venable
Sanitarian.

Sketch of tank and line showing distance from dwelling and well on subject property and on adjoining property.