06377

I

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130, Article 13C)

OWNER OR CONTRACTOR Rick Blankenship DATE 7/12/91 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Old Mountain Rd from Troutman, Lf on Southwood House on backside off road on Lf.) S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2½

Garbage Disposal Unit Yes (✓) No ( )

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area _____

Character & Porosity of Soil Prov Suitable

Percolation Rate 0.5 spd/ft²


Topography 2-6%

Depth to Water Table 70"+

Rock or other impervious formations one noted.

WOODS

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:

No. of Lines 5

Sq. Ft. 240 Linear Ft. 720

Depth of Stone in Lines 12"

Water Supply: Individual (✓)

Public ( )

Installed by Donald Looby

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS: layout change OK by TSB.

CERTIFICATE OF COMPLETION BY _____ DATE 7/17/91

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold