IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Barry Meadows DATE 7/12/78 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Southwood Sub Division off of old Mountain Rd. S. R. No. _____

SUBDIVISION NAME Southwood LOT NO. 45 SECTION OR BLOCK NO. _____


House (+) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2 1/2

Garbage Disposal Unit Yes (+) No ( )
Auto. Dishwasher Yes (+) No ( )
Auto. Wash. Machine Yes (+) No ( )
Site Suitable Yes (+) No ( )

Lot Area 3/4 Acre

Character & Porosity of Soil Red Suitable C & BR
Percolation Rate _____
Topography Slope
Depth to Water Table Low
Rock or other impervious formations None



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 10"
Water Supply: Individual (+)
Public ( )

Installed by Hoke Septic Tank Co

4X4 Septic Tank
3X50 Ditch
10" Stone
Washer Drain

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 7/12/78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold