IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Gene Troutman Bldr. DATE 11-19-73 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Buffalo Shoals Rd To Old Mountain Rd. T.L. Southwood Development on Rt. Before South School S. R. No. _____


SUBDIVISION NAME South Wood LOT NO. 18 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 4

Garbage Disposal Unit	Yes (✓)	No ( )	Character & Porosity of Soil	Red Clay
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	DC Perk Test
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Slightly sloping to back
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	Low
			Rock or other impervious formations	None

Lot Area 22000 sq ft.



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 712½ Linear Ft. 285
Depth of Stone in Lines _____
Water Supply: Individual (✓)
Public ( )

Installed by Lackey Bro

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY E. G. Stevenson DATE 11-19-73

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold