IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Ed. Bryan - Bldr. DATE 6/3/77 PERMIT NO. _____

PHONE Business _____ Home _____

LOCATION Southwood - Sub-Division off of old Mountain Rd S. R. No. _____

SUBDIVISION NAME Southwood LOT NO. 16 SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 4 No. Bathrooms 2½

Garbage Disposal Unit Yes (✓) No ( )
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Lot Area 20,000 sq ft

Character & Porosity of Soil Red Clay
Percolation Rate _____
Topography Slope Low
Depth to Water Table _____
Rock or other impervious formations None



Plot of System

Size of Tank 1500 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )

Installed by Lake Septic Tank Co.

IMPROVEMENTS PERMIT BY _____

COMMENTS: Surface water and water from downspouts should be diverted away from septic tank and lines. This is very important!

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 6/3/77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold