Rose M. Lundy 206242

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Ed. Bryan - Bldr. DATE 6/3/77 PERMIT NO. _____

PHONE: Business _____ House _____


LOCATION Southwood - Sub-Division off of old Mountain Rd S. R. No. _____

SUBDIVISION NAME Southwood LOT NO. 16 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 4 No. Bathrooms 2½

Garbage Disposal Unit	Yes (✓)	No ( )	Character & Porosity of Soil	Red Clay
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Slope
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	Low
Lot Area 20,000 sq ft			Rock or other impervious formations	None



Plot of System

Size of Tank 1500 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 900 Linear Ft. 300

Depth of Stone in Lines 12"

Water Supply: Individual (✓)

Public ( )

Installed by Lake Septic Tank Co.

Location of the proposed 26 x 20' shed addition does not appear to impact the existing on-site septic system or well. NOTE: _____

REHS Date: 10/08/14

ICHD-Environmental Health Division

IMPROVEMENTS PERMIT BY _____

COMMENTS: Surface water and water from downspout should be diverted away from septic tank and lines. This is very important!

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 6/3/77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold