IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Eugene Troutman DATE 4/24/78 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Southwood Sub-Division W/S of old Mountain Rd S. R. No. _____


SUBDIVISION NAME Southwood LOT NO. 27 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No ( )	Character & Porosity of Soil	Prob Suitable
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Slope to road Low
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	
			Rock or other impervious formations	None

Lot Area 20 000 sq ft



Plot of System

Size of Tank 1500 Gals.

Nitrification Field:
No. of Lines 4
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 10"

Water Supply: Individual (✓)
Public ( )

Installed by Hoke Septic Tank Co.

IMPROVEMENTS PERMIT BY _____

COMMENTS: Lot should be graded so water will not stand on back of lot.

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 4/24/78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold