IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Kay Robbins DATE 4/20/79 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Southwood Sub Division off of Old Mountain Rd. 2nd House on L. S. R. No. _____

SUBDIVISION NAME Southwood LOT NO. 29 SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms _____ No. Bathrooms _____

Garbage Disposal Unit	Yes ( )	No ( )
Auto. Dishwasher	Yes ( )	No ( )
Auto. Wash. Machine	Yes ( )	No ( )
Site Suitable	Yes ( )	No ( )

Lot Area _____

Character & Porosity of Soil _____
Percolation Rate _____
Topography _____
Depth to Water Table _____
Rock or other impervious formations _____



Plot of System

Size of Tank Repair Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 600 Linear Ft. 200
Depth of Stone in Lines 16"
Water Supply: Individual (✓)
Public ( )

Installed by Donald Lackey

IMPROVEMENTS PERMIT BY _____

COMMENTS: Downspouts and all surface water possible to be diverted away from Septic Tank and drainfield.

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 4/20/79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold