IREDELL COUNTY HEALTH DEPARTMENT

County Building — Phone 1164 — Statesville, N. C.

PERMIT TO INSTALL SEPTIC TANK

Permit No. 819 Permit Date 9-29- 1947

Owner W A Davidson Address Wallace Springs Rd

Tenant " Address "

Installed by Clyde Hoke Address Statesville

Location of property Wallace Springs Rd

Kind of tank Concrete Capacity 200 l Length of trench 200'


NOTIFY HEALTH DEPARTMENT AT LEAST EIGHT HOURS BEFORE TANK IS TO BE INSPECTED

There must be at least 200 feet of tile in line, with cinder pit at end.

Final Inspection 9-29-47 194 Approved (✓) Disapproved ( )

Remarks:

First five feet of line from outlet should be of cast iron soil pipe.



Sketch of tank and line showing distance from dwelling and well on subject property and on adjoining property.

J E Verble
Sanitarian.