10776.

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Roy S. MORRISON DATE 4-26-90 PERMIT NO. 35-7-1-4.

PHONE: Business _____ Home _____

LOCATION Hwy. 115 to Pluss Fountain, go north approx. ½ mi. past South Iredell School on left at 2 mile Jones-House back off road

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____ S. R. No. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2.5

Garbage Disposal Unit Yes ( ) No (✓) Character & Porosity of Soil Poor Sandy Clay


Auto. Dishwasher Yes (✓) No ( ) Percolation Rate 4 min/in

Auto. Wash. Machine Yes (✓) No ( ) Topography 2-4% slope

Site Suitable Yes (✓) No ( ) Depth to Water Table 10'+

Lot Area 10 acres. Rock or other impervious formations None observed

Basement with Plumbing LATER Basement without Plumbing _____ No Basement



Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 2

Sq. Ft. 700 Lineal Ft. 300

Depth of Stone in Lines 12

Water Supply: Individual (✓)

Public ( )

Installed by James Hudler

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

Plot of System

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Steve Brown DATE 5-16-90.

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold