IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR VERLIE HOLLAND JR. DATE 2-9-81 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Old Statesville Rd. - 1/2 mile north of South Iredell School - Southwood Dev. on left, go into dev., take 1st left & 2nd house on left. S. R. No. _____

SUBDIVISION NAME Southwood LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes (✓)	No ( )
Auto. Dishwasher	Yes (✓)	No ( )
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area Ample

Character & Porosity of Soil Red clay
Percolation Rate 5 gal/sq. ft.
Topography 6-15%
Depth to Water Table 16' +
Rock or other impervious formations none observed.

_____ Basement with Plumbing ✓ Basement without Plumbing _____ No Basement



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 100
Depth of Stone in Lines 16"
Water Supply: Individual (✓)
Public ( )

Installed by Eddie Younts

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS: Pipe off downspouts from gutters away from S. T. system.

CERTIFICATE OF COMPLETION BY Steve Brown

EXISTING SYSTEM CHECKED BY: _____ DATE 2-9-81

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.
Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit. DATE _____

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold