Larry Jenkins
Builder

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Allen Talbert DATE 3-22-75 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Turn on E. Mombo Rd at Troutman T.R. into Parkwood Acres. House on R. at end of street S. R. No. _____

SUBDIVISION NAME Parkwood Acres LOT NO. _____ SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area 125 x 180

Character & Porosity of Soil Cecil Clay ([redacted])
Percolation Rate _____
Topography Slight Slope to North Side
Depth to Water Table Low
Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Robert Hoke
R. E. Foy

IMPROVEMENTS PERMIT BY _____

COMMENTS: Surface water and water from downspouts Need to be diverted away from Tank and Lines. Gas line and Power line cross lines

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 3-22-75

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold