SHEET ____ OF ____

DEPARTMENT OF ENVIRONMENT, HEALTH & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

DRAFT

PROPERTY I.D.#: _____
DATE: 5-17-95
COUNTY: Iredell

SOIL SITE EVALUATION FOR ON-SITE WASTEWATER SYSTEM

APPLICANT: Brian Yount
ADDRESS: _____
OWNER ___ AGENT ___ PHONE: _____
APPLICATION DATE: _____ DATE EVALUATED 5-17-95
PROPOSED FACILITY: 3 Bedroom House
PROPERTY SIZE _____

LOCATION OF SITE: Margrill Acres
WATER SUPPLY: On-site Well ✓ Comun. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS./ SLOPE(%)	HORIZON DEPTH (IN)	.1941 TEXTURE	.1941 STRUCTURE	.1941 MINERALOGY	MATRIX COLOR	MOTTLE COLOR	OTHER PROFILE FACTORS
1	10-14%	0-8"	l	gr	1:1			.1942 Wetness Cond. - S
	L	8"-20"	C	Abk	1:1			.1943 Depth/.1956 Sapr. - 24" U
		20"-24"	C/Sap.	Abk/m	1:1			.1944 Restrictive Hori. - NA
		24"-46"	Sap.	m	1:1			.1948 Profile Class. - U
								Profile LTAR -
2	10-14%	0-4"	l	gr.	1:1			.1942 Wetness Cond. - S
	L	4"-20"	C	Abk	1:1			.1943 Depth/.1956 Sapr. - 24" U
		20"-24"	C/Sap.	Abk/m	1:1			.1944 Restrictive Hori. - NA
		24"	Rock	m	1:1			.1948 Profile Class. - U
								Profile LTAR -
3	10-14%	0-3"	l	gr	1:1			.1942 Wetness Cond. - S
	L	3"-18"	C	Abk	1:1			.1943 Depth/.1956 Sapr. - 22" U
		18"-22"	C/Sap.	Abk/m	1:1			.1944 Restrictive Hori. - 22" U
		22"-	Rock	m	1:1			.1948 Profile Class. - U
								Profile LTAR -
4	10-14%	0-5"	l	gr	1:1			.1942 Wetness Cond. - S
	L	5"-30"	C	Abk	1:1			.1943 Depth/.1956 Sapr. - NA
		30"-33"	C/Sap.	Abk/m	1:1			.1944 Restrictive Hori. - 33" U
		33"	Rock	m	1:1			.1948 Profile Class. - U
								Profile LTAR -

VARIABLE SPACE (.1945) _____ OTHER FACTORS (.1945) _____ SITE CLASSIFICATION (.1948) _____

SYSTEM TYPE _____ LONG-TERM ACCEPTANCE RATE(S) _____

EVALUATED BY: Michael J Dennen OTHER(S) PRESENT: _____

COMMENTS: Application Blank, House not staked off, Basement already out. He Call back when completed