ADDRESS: Brian Yount APPLICATION DATE: DATE EVALUATED: 6-13-95.

PROPOSED FACILITY: 3 Bedroom House

PROPERTY SIZE:

LOCATION OF SITE: Margaret Acres

WATER SUPPLY: On-site Well ✓ Comm. Well Public Other EVAL METHOD: Auger Boring ✓ Pit Cut

PROFILE	1940 LANDSCP POS / SLOPE(%)	HORIZON DEPTH (IN)	1941 (#1) TEXTURE	(#2) STRUCTURE	(#3) MINERALOGY	MATRIX COLOR	MOTTLE COLOR	OTHER PROFILE FACTORS
	12-19%	0-4"	cl	gr	1:1			1942 Wetness Cond. · S
	L	4"-38"	C	ss,sp Abk	1:1			1943 Depth/ 1956 Sapr. · 44" PS
		38"-44"	C/sap	ss,sp Abk/m	1:1			1944 Restrictive Hori. · NA
		44"-48"	Sap/weathered Rock m		1:1			1948 Profile Class. · PS
								Profile LTAR · .25
	13-15%	0-5"	cl	gr	1:1			1942 Wetness Cond. · S
	L	5"-36"	C	ss,sp Abk	1:1			1943 Depth/ 1956 Sapr. · 45" PS
		36"-45"	C/sap	ss,sp Abk/m	1:1			1944 Restrictive Hori. · NA
		45"-48"	Sap	m	1:1			1948 Profile Class. · PS
								Profile LTAR · .25
	13-15%	0-4"	cl	gr	1:1			1942 Wetness Cond. · S
	L	4"-40"	C	ss,sp Abk	1:1			1943 Depth/ 1956 Sapr. · NA
		40"-48"	C/sap	ss,sp Abk/m	1:1			1944 Restrictive Hori. · NA
								1948 Profile Class. · PS
								Profile LTAR · .25
	13-15%	0-6"	cl	gr	1:1			1942 Wetness Cond. · S
	L	6"-39"	C	ss,sp Abk	1:1			1943 Depth/ 1956 Sapr. · 44" PS
		39"-44"	C/sap	ss,sp Abk/m	1:1			1944 Restrictive Hori. · NA
		44"-46"	Sap/weathered Rock m		1:1			1948 Profile Class. · PS
								Profile LTAR · .25

AVAILABLE SPACE (1945): S OTHER FACTORS (1946): SITE CLASSIFICATION (1948): PS

SYSTEM TYPE: conventional, gravity fed LONG-TERM ACCEPTANCE RATE(S): .25 gpd/ft²

EVALUATED BY: OTHER(S) PRESENT: Felix Webster

COMMENTS:

0029 11