IREDELL COUNTY HEALTH DEPARTMENT

11653

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR STEVEN CHUMLEY DATE 7/26/90 PERMIT NO. 6B-6-A-7

PHONE: Business _____ Home _____

LOCATION US 21S TL CUMBERLAND TL WATER TROUGH
1/4 MI ON LEFT S. R. No. _____

SUBDIVISION NAME SABLE POINT LOT NO. 7 SECTION OR BLOCK NO. _____


House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	CLAYEY	
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	2-6 7	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	10%	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	ROCK 36"	
			Rock or other impervious formations		

Lot Area .9 AC

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )

Installed by KEN DELINGER

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Steve Hines / J.C. Moore DATE 7/26/90

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold