IREDELL COUNTY HEALTH DEPARTMENT

Statesville Phone TR 3-7271 Mooresville Phone NO 3-1271

PERMIT TO INSTALL SEPTIC TANK

Permit NO. _____ Permit Date Nov 19 1960

Owner Moose Lodge #687 Address Barium Springs

Installed By C Hoke Address R7 -

Location of Property —

Tank		Capacity		Length of Lines		Fixtures	
Block	( )	800	( )	150'	( )	No. of Baths	( )
Precast	( )	900	( )	175'	( )	Dishwasher	( )
		1000	( )	200'	( )	Garbage Grdr.	( )
		1100	( )	225'	( )	Auto-Washer	( )
		1200	( )	250'	( )	Other	
		Other		Other 400 ft.			

NOTIFY HEALTH DEPARTMENT AT LEAST EIGHT HOURS BEFORE TANK IS TO BE INSPECTED.

Final Inspection 11-4 1960 Approved (✓) Disapproved ( )

Remarks Repair to drain line - used 175 ft. line in stepdowns to tee in flat ground. tank needs pumped at least 2 times per yr.

(Over)

Sketch of Installation

RT

Sanitarian