HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: _____
PROPERTY RECORDED: _____
COUNTY: _____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Bob Compton OWNER: AGENT: PHONE: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: _____
_____ PROPOSED FACILITY: _____
_____ PROPERTY SIZE: _____
LOCATION OF SITE: Lot 6A Sable Point
WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ___ Other _____ EVAL. METHOD: Auger Boring ___ Pit ___ Cut ___

PROFILE #	1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	1941 (a)(1) TEXTURE	1941 (a)(2) STRUCTURE	1941 (a)(3) MINERALOGY		
1	Linear 15%	0 to 6	L	GR		1942 WETNESS CONDITION	N/A
		6 to 24	C	SBK	1:1	1943/ 1956 SAPROLITE	N/A
		24 to 32	CL	weak SBK	1:1	1944 RESTRICTIVE HORIZON	N/A
		32 to 48	B/C			1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	.3
2	Linear 20%	0 to 6	L	GR		1942 WETNESS CONDITION	N/A
		6 to 24	C	SBK	1:1	1943/ 1956 SAPROLITE	N/A
		24 to 48	CL	weak SBK	1:1	1944 RESTRICTIVE HORIZON	N/A
						1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	.3
3	Linear 20%	0 to 6	L	GR		1942 WETNESS CONDITION	N/A
		6 to 24	C	SBK	1:1	1943/ 1956 SAPROLITE	N/A
		24 to 36	CL	weak SBK	1:1	1944 RESTRICTIVE HORIZON	N/A
		36 to 48	B/C			1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	.3
4						1942 WETNESS CONDITION	
						1943/ 1956 SAPROLITE	
						1944 RESTRICTIVE HORIZON	
						1948 PROFILE CLASSIFICATION	
						PROFILE LTAR	
5						1942 WETNESS CONDITION	
						1943/ 1956 SAPROLITE	
						1944 RESTRICTIVE HORIZON	
						1948 PROFILE CLASSIFICATION	
						PROFILE LTAR	

AVAILABLE SPACE (1945) Yes SITE CLASSIFICATION (1949) _____ SITE LONG-TERM ACCEPTANCE RATE .3
OTHER FACTORS (1946) _____ SYSTEM TYPE _____
EVALUATED BY: R.C. Moore OTHER(S) PRESENT Bob Compton
COMMENTS _____

DRAFT