HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: ____
PROPERTY RECORDED: ____
COUNTY: ____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Iredell Vocational OWNER: AGENT: PHONE: ____
ADDRESS: workshop APPLICATION DATE: ____ DATE EVALUATED: ____
PROPOSED FACILITY: ____
PROPERTY SIZE: ____
LOCATION OF SITE: ____
WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ___ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY	
1	6% Linear	0 to 4	L	GR		.1942 WETNES CONDITION - N/A
		4 to 36	C	ABK	1:1	.1943/.1956 SAPROLITE - N/A
		36 to 48	C	weak ABK	1:1	.1944 RESTRICTIVE HORIZON - N/A
						.1948 PROFILE CLASSIFICATION - PS
						PROFILE LTAR - .3
2	Linear 6%	0 to 4	L	GR		.1942 WETNES CONDITION - N/A
		4 to 36	C	ABK	1:1	.1943/.1956 SAPROLITE - N/A
		36 to 48	C	weak ABK	1:1	.1944 RESTRICTIVE HORIZON - N/A
						.1948 PROFILE CLASSIFICATION - PS
						PROFILE LTAR - .3
3	Linear 12%	0 to 4	L	GR	1:1	.1942 WETNESS CONDITION - N/A
		4 to 24	C	SBK	1:1	.1943/.1956 SAPROLITE - N/A
		24 to 36	C	weak ABK	1:1	.1944 RESTRICTIVE HORIZON - N/A
		36 to 48	Transition			.1948 PROFILE CLASSIFICATION - PS
						PROFILE LTAR - .3
4						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -
5						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -

AVAILABLE SPACE (.1945) yes SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: .3
OTHER FACTORS(.1946) ____ SYSTEM TYPE Conv. Conventional
EVALUATED BY: ____ OTHER(S) PRESENT: Thomas Wilson
COMMENTS: ____

DRAFT