DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY RECORDED: _____
COUNTY: _____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Gary Estes OWNER: __ AGENT: __ PHONE: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: _____
PROPOSED FACILITY: _____
PROPERTY SIZE: _____
LOCATION OF SITE: _____
WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ___ Other _____ EVAL. METHOD: Auger Boring ___ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY	
1	Linear 12%	0 to H	L	GR		.1942 WETNES CONDITION - N/A
		H to 48	C	SBK	SEAP	1943/.1956 SAPROLITE - PS
						.1944 RESTRICTIVE HORIZON - PS
						.1948 PROFILE CLASSIFICATION - PS
						PROFILE LTAR - .3
2	Linear 12%	0 to 4	L	GR		.1942 WETNES CONDITION - PS
		4 to 24	C	SBK	SEAP	.1943/.1956 SAPROLITE - PS
		24 to 48	CL	WSBK	SEAP	1944 RESTRICTIVE HORIZON - PS
						1948 PROFILE CLASSIFICATION - PS
						PROFILE LTAR - .3
3	Linear 10%	0 to 4	L	GR		1942 WETNESS CONDITION - PS
		4 to 24	C	SBK	SEAP	1943/ 1956 SAPROLITE - PS
		24 to 48	CL	WSBK	SEAP	.1944 RESTRICTIVE HORIZON - PS
						1948 PROFILE CLASSIFICATION - PS
						PROFILE LTAR - .3
4						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -
5						.1942 WETNESS CONDITION -
						1943/.1956 SAPROLITE -
						1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -

AVAILABLE SPACE (.1945) Yes SITE CLASSIFICATION (.1948): _____ SITE LONG-TERM ACCEPTANCE RATE: .3
OTHER FACTORS(.1946) _____ SYSTEM TYPE _____
EVALUATED BY: L.C. Moore OTHER(S) PRESENT: _____
COMMENTS: _____

DRAFT