IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Larry Millsaps DATE 3/25/77 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Buffalo Shoals Rd. T.L. just outside City Limits on Rd # 1345 Cross R.R. Railroad T.R. Trailer Park at End of Rd S. R. No. _____

SUBDIVISION NAME Tony's Trailer Park LOT NO. _____ SECTION OR BLOCK NO. _____

Last 2 Trailers -

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms _____ No. Bathrooms _____

Garbage Disposal Unit Yes ( ) No ( )

Auto. Dishwasher Yes ( ) No ( )

Auto. Wash. Machine Yes ( ) No ( )

Site Suitable Yes ( ) No ( )

Lot Area _____


Character & Porosity of Soil Cecil Clay

Percolation Rate _____

Topography Slight Slope

Depth to Water Table Low

Rock or other impervious formations None



Plot of System

Size of Tank 1500 Gals.

Nitrification Field:

No. of Lines 4

Sq. Ft. 1250 Linear Ft. 500

Depth of Stone in Lines 10"

Water Supply: Individual (✓)

Public ( )

Installed by Lawrence Pearson

IMPROVEMENTS PERMIT BY _____

COMMENTS: Too Much Fall in lines. Dirt Dam installed to Compensate for extra fall. To be graded over lines so surface water will drain away from system.

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 3/25/77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold