IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Richard Shaver DATE 6/28/79 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hwy 21 S. T.R at Hill Haven Rest Home
1st House on Rt S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House ( ) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms _____ No. Bathrooms _____

Garbage Disposal Unit	Yes ( )	No ( )	
Auto. Dishwasher	Yes ( )	No ( )	
Auto. Wash. Machine	Yes ( )	No ( )	
Site Suitable	Yes ( )	No ( )	

Character & Porosity of Soil _____
Percolation Rate _____
Topography _____
Depth to Water Table _____
Rock or other impervious formations _____

Lot Area _____



Plot of System

Well
Size of Tank Repair Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 600 Linear Ft. 200
Depth of Stone in Lines 16"
Water Supply: Individual (+)
Public ( )

Installed by Hake Septic Tank Co.

IMPROVEMENTS PERMIT BY _____

COMMENTS: Tank Pumped - Tee Checked and Well Tile Put over Tank for Maintenance Purposes

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 6/28/79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold