IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR John Duchinski DATE 1-14-75 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 21 S. on Rt. Just-Pit Boys Land Camp.

S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes ( )	No (✓)	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes ( )	No ( )	

Lot Area _____

Character & Porosity of Soil Existing


Percolation Rate _____

Topography _____

Depth to Water Table _____

Rock or other impervious formations _____

Existing System Installed 7-23-69



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 2
Sq. Ft. 562½ Linear Ft. 225
Depth of Stone in Lines 6"

Water Supply: Individual (✓)
Public ( )

Installed by Clyde Hobbs

IMPROVEMENTS PERMIT BY _____

COMMENTS: Septic Tank System O.K. Not Surfacing at time of inspection.

CERTIFICATE OF COMPLETION BY _____ DATE 1-14-75

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold