Ivenhoe Bldr.

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR W. C. Bradshaw DATE 8-22-74 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Wallace Springs Rd. Just outside City limits T.R. on Rd 1390. Go to End of Street. House on L S. R. No. 1390

SUBDIVISION NAME Washington Heights LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes (✓) No ( )

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area 150 X 155


Character & Porosity of Soil Red Clay

Percolation Rate No Perk Test

Topography Slight Slope to back

Depth to Water Table Low

Rock or other impervious formations None



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 630 Linear Ft. 252

Depth of Stone in Lines 10"

Water Supply: Individual ( )

Public (✓)

Installed by Ivenhoe Bldg.

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 8-22-74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold