HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#:
PROPERTY RECORDED:
COUNTY:

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: June Wooten OWNER: AGENT: PHONE:
ADDRESS: APPLICATION DATE: DATE EVALUATED:
PROPOSED FACILITY:
PROPERTY SIZE:
LOCATION OF SITE:
WATER SUPPLY: On-Site Well Comm. Well Public Other EVAL. METHOD: Auger Boring Pit Cut

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY	
1	Linear 8%	0 to 4"	CL	GR		1942 WETNESS CONDITION - N/A
		4 to 38"	C	SBK	1:1	1943/.1956 SAPROLITE - N/A
		38 to 48"	C	weak SBK	1:1	1944 RESTRICTIVE HORIZON - N/A
						.1948 PROFILE CLASSIFICATION - PS
						PROFILE LTAR - .35
2	Linear 8%	0 to 6	L	GR		1942 WETNESS CONDITION - N/A
		6 to 42	C	SBK	1:1	1943/.1956 SAPROLITE - N/A
		42 to 48	C	weak SBK	1:1	1944 RESTRICTIVE HORIZON - N/A
						1948 PROFILE CLASSIFICATION - PS
						PROFILE LTAR - .35
3	Linear 6%	0 to 6	L	GR		1942 WETNESS CONDITION - N/A
		6 to 44	C	SBK	1:1	1943/.1956 SAPROLITE - N/A
		44 to 48	C	weak SBK	1:1	1944 RESTRICTIVE HORIZON - N/A
						1948 PROFILE CLASSIFICATION - PS
						PROFILE LTAR - .35
4						1942 WETNESS CONDITION -
						1943/.1956 SAPROLITE -
						1944 RESTRICTIVE HORIZON -
						1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -
5						1942 WETNESS CONDITION -
						1943/.1956 SAPROLITE -
						1944 RESTRICTIVE HORIZON -
						1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -

AVAILABLE SPACE (.1945) Yes SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: 1.35
OTHER FACTORS(.1946) SYSTEM TYPE David Burrell Keith Burrell
EVALUATED BY: C. Moore OTHER(S) PRESENT:
COMMENTS:

DRAFT

0023088