IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Albert Payne - VFW Bldg DATE 23 May 74 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 21 S - 1st Bldg on Right after crossing Third Creek

S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House ( ) Mobile Home ( ) Business ( ) Other Retirement 200 seating capacity

No. Bedrooms _____ No. Bathrooms _____

Garbage Disposal Unit	Yes ( )	No ( )	
Auto. Dishwasher	Yes ( )	No ( )	
Auto. Wash. Machine	Yes ( )	No ( )	
Site Suitable	Yes ( )	No ( )	

Lot Area _____

Character & Porosity of Soil Sand Loam
Percolation Rate 30 min
Topography Level
Depth to Water Table 8 ft.
Rock or other impervious formations None



Plot of System Hwy 21 S.

Size of Tank 2-1500 gal Tanks Gals.
Nitrification Field:
No. of Lines 9
Sq. Ft. 2295 Linear Ft. 765
Depth of Stone in Lines 10"
Water Supply: Individual ( )
Public (✓)

Installed by James Hartness

IMPROVEMENTS PERMIT BY _____

COMMENTS: Solid Steel pipe across street.

CERTIFICATE OF COMPLETION BY William M. Howard DATE 31 May 74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold