No Copy on File

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Jemmy Hoke DATE 6-28-76 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Knollwood Sub. Division off of Hwy #21 at 3rd Creek S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms _____ No. Bathrooms _____

Garbage Disposal Unit	Yes ( )	No ( )
Auto. Dishwasher	Yes ( )	No ( )
Auto. Wash. Machine	Yes ( )	No ( )
Site Suitable	Yes ( )	No ( )

Lot Area _____


Character & Porosity of Soil _____

Percolation Rate _____

Topography _____

Depth to Water Table _____

Rock or other impervious formations Repair



Plot of System

Size of Tank Repair Gals.

Nitrification Field:

No. of Lines 2

Sq. Ft. 375 Linear Ft. 150

Depth of Stone in Lines 10" +

Water Supply: Individual ( )

Public (✓)

Installed by Hoke Septic Tank

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 6-28-76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold