IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Bill Brendle DATE 11/30/78 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hwy 21 S just outside City limits T.R. on #1491
House on L. near Top of Hill. S. R. N. _____

SUBDIVISION NAME Knollwood LOT NO. 24-25 SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 3

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes (✓)	No ( )
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area 40,000 sq ft +

Character & Porosity of Soil Prev Suitable
Percolation Rate _____
Topography Slope Low
Depth to Water Table _____
Rock or other impervious formations None



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 750 Linear Ft. 300
Depth of Stone in Lines 10"
Water Supply: Individual ( )
Public (✓)
Community

Installed by Bill Brendle & Cecil Forsythe

IMPROVEMENTS PERMIT BY _____

COMMENTS: Maple Tree near start of line should be removed. Foundation drain and downspouts should be diverted away from Tank + lines.

CERTIFICATE OF COMPLETION BY E. G. Stevenson DATE 11/30/78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold