CITY OF STATESVILLE.

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR CLINTON H. SETZER DATE 8-28-90 PERMIT NO. 15A

PHONE: Business _____ Home _____

LOCATION Shelton Ave. south - T.R. on Jerico Rd. 2nd St. at Welcome Bapt. Church T.R. on Lidecoat Rd. - go 1/2 mile on R. S. R. No. _____

SUBDIVISION NAME HOLLYWOOD DEV. LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No ( )

Auto. Dishwasher Yes ( ) No ( )

Auto. Wash. Machine Yes ( ) No ( )

Site Suitable Yes ( ) No ( )

Character & Porosity of Soil Prev. Suitable.

Percolation Rate Prev. Inst.


Topography Level

Depth to Water Table 12+

Rock or other impervious formations scattered rock.

Lot Area 100' X 247'

_____ Basement with Plumbing _____ Basement without Plumbing ___ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 720 Lines Ft. 240

Depth of Stone in Lines 24"

Water Supply: Individual ( )

Public ( )

Installed by J. C. Forsyth

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Steve Brown

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Steve Brown DATE 8-28-90

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold