IREDELL COUNTY HEALTH DEPARTMENT

County Building — Phone 1164 — Statesville, N. C.

PERMIT TO INSTALL SEPTIC TANK

Permit No. 411 Permit Date 4/12 194

Owner C W Pearson Address R-6 Statesville

Tenant C.W. Pearson's Store & Cafe Address R 6

Installed by C W Pearson's Address

Location of property Near Concrete Plant

Kind of tank Concrete Capacity 1000 Length of trench 120'


NOTIFY HEALTH DEPARTMENT AT LEAST EIGHT HOURS BEFORE TANK IS TO BE INSPECTED

There must be at least 200 feet of tile in line, with cinder pit at end.

Final Inspection Oct 31 194 6. Approved (✓) Disapproved ( )

Remarks:

First [illegible] feet of line from outlet should be of cast iron soil pipe.



J. E. Verble

Sanitarian.

Sketch of tank and line showing distance from dwelling and well on subject property and on adjoining property.