IREDELL COUNTY HEALTH DEPARTMENT

County Building — Phone 1164 — Statesville, N. C.

PERMIT TO INSTALL SEPTIC TANK

Permit No. _____ Permit Date 8 Sept 1949

Owner CO-OP MILLS, INC. Address FRONT ST, STATESVILLE

Tenant _____ Address _____

Installed by CLYDE HOKE Address STATESVILLE

Location of Property FRONT ST. - TAYLORSVILLE HWY.

Kind of Tank POURED Capacity 1 1/2 GAL Length of trench 140' - 30" WIDTH

NOTIFY HEALTH DEPARTMENT AT LEAST EIGHT HOURS BEFORE TANK IS TO BE INSPECTED


There must be at least 200 feet of tile in line, with cinder pit at end.

Final Inspection 8 SEPT 1949 Approved X Disapproved ( )

Remarks: OLD LINE TIED IN

DITCH OF 30" X 30" EQUIVALENT TO 280 LINEAL FT.

First five feet of line from outlet should be of cast iron soil pipe.



Sanitarian.

Sketch of tank and line showing distance from dwelling and well on subject property and on adjoining property.