DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of _
PROPERTY ID #: 4734 90 3175
COUNTY: IREDELL

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: BUILDING MATERIAL WHSL/RETAIL APPLICANT: L.R. WOOTEN
ADDRESS: 1474 WINSTON AVE, STVL, NC APPLICATION DATE: 4-18-01 DATE EVALUATED: 5-10-01
PROPOSED FACILITY: WAREHOUSE PROPOSED DESIGN FLOW (.1949): 2001 PROPERTY SIZE: 4.998 ACRES
LOCATION OF SITE: 1474 WINSTON AVE, STATESVILLE PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☑ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL. CLASS & LTAR
1	L 7%	0-8	GR CL	FR SEP					PS 0.3
		8-36	SBK C	FI SEP					
		36-48	SBK CL	FR SEP					
2	L 7%	0-6	GR CL	FR SEP					PS 0.3
		6-38	SBK C	FI SEP					
		38-48	SBK CL	FR SEP					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	S	S
System Type(s)	II	III
Site LTAR	0.3	0.3

OTHER FACTORS (.1946): NONE
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: S. HEDRICK
OTHER(S) PRESENT: L.R. WOOTEN, JERRY ALFORD