E WASTEWATER SECTION

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

ER: KENNETH McCANN APPLICANT: SAME
ESS: 317 GRASSY KNOB U.G. APPLICATION DATE: 6-11-98 DATE EVALUATED: 6-29-98
OSED FACILITY: 3BR W/C.S. PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 82,979 SF
TION OF SITE: COUNTRY ENDING # 12 PROPERTY RECORDED:
ER SUPPLY: ☐ Private ☑ Public ☐ Well ☐ Spring ☐ Other
UATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut
OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

.1940 LAND-SCAPE POSITION/ SLOPE %	HORI-ZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
L 3%	0-6	GR / SCL	VFR / 1:1	—	S	—	—	0.3
	6-48	SBK / C	FR-FI / 1:1					PS
H 4%	0-6	GR / SCL	VFR / 1:1	—	S	—	—	PS
	6-48	SBK / C	FR / 1:1					0.3

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	S	S
System Type(s)	CONV GRAV	CONV GRAV.
[illegible]	0.3	0.3

OTHER FACTORS (.1946): NONE
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: S. H. DRICK
OTHER(S) PRESENT: KENNETH McCANN