IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Stewart Peray DATE April 19, 1977 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 115 N., T.L. on old Wilkesboro Rd just past Monnett Mart, last house on Rt before Woodmont S. R. No. _____


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Cecil Clay	
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	none	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2-6% slope	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	est	
			Rock or other impervious formations	none observed	

Lot Area Acreage



Plot of System

Size of Tank existing Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 625+ Linear Ft. 250
Depth of Stone in Lines 10"+
Water Supply: Individual (✓)
Public ( )

Installed by Henry Sigmon

IMPROVEMENTS PERMIT BY _____

COMMENTS: New plastic sanitary "T" installed

CERTIFICATE OF COMPLETION BY Andrew E. Causey DATE 4/19/77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold