Heritage Bldrs

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Herb. Poole DATE 3/19/79 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION _____

S. R. No. _____

SUBDIVISION NAME Northmont LOT NO. 13 SECTION OR BLOCK NO. _____

House (+) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes (+) No ( )

Auto. Dishwasher Yes (+) No ( )

Auto. Wash. Machine Yes (+) No ( )

Site Suitable Yes (+) No ( )

Lot Area 20,000 Sq ft


Character & Porosity of Soil Prov Suitable

Percolation Rate _____

Topography Slope to Front

Depth to Water Table Low

Rock or other impervious formations None



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:

No. of Lines 4

Sq. Ft. 400 Linear Ft. 300

Depth of Stone in Lines 16"

Water Supply: Individual ( )

Public (+)

Installed by Hoke Septic Tank Co

IMPROVEMENTS PERMIT BY _____

COMMENTS: Divert Surface water away from Septic Tank & lines. This is important.

CERTIFICATE OF COMPLETION BY E. A. Stutesman DATE 3/19/79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold