DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Kimberly Johnson APPLICANT: Kimberly Johnson
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 6/14/01
PROPOSED FACILITY: 2BR MH PROPOSED DESIGN FLOW (.1949): 240 PROPERTY SIZE: _____
LOCATION OF SITE: _____ PROPERTY RECORDED: no
WATER SUPPLY: ☒ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTAF
1	Linear	0-22	CL SBK	FR FI	SS SP	SExp			.35
		22-31	CL - SBK Sm*	Fr SS SP SExp					
		31-48	CL - SBK mm	SS SP FR					
2	4% Linear	0-7	C SBK	FR SS SP	SExp				.35
		7-16	CL "SBK mica	Fr SS SP SExp					
		16-24	CL SBK mm	"Fr " "					
		24-	SAP (G)	LS-GR NS NP NExp					
3	5½% Linear	0-5	ls g	NS NP NExp					.35
		5-10	c/cc SBK	SS SP SExp					
		10-30	cl WK SBK						
		30-48	SaP (gravel)	(cl) g. NS NP NExp					
4					Sm - Some mica mm - Many mica				

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	Gravity, Conv	Grav. 25% Red
Site LTAR	.35	.35

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: Bill Johnson
OTHER(S) PRESENT: Kimberly Johnson