DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET ___ OF ___
PROPERTY I.D.#: 9A-6-A-105
PROPERTY RECORDED:
COUNTY: IREDELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: JACK HINES OWNER: ✓ AGENT: PHONE: 873-5871 / /
ADDRESS: 131 DJ DRIVE APPLICATION DATE: 4/19/95 DATE EVALUATED: 4/21/95
STATESVILLE NC PROPOSED FACILITY: 3 BR HOUSE
28677 PROPERTY SIZE: 3.75 ACRES
LOCATION OF SITE: LOTS 105-109 NORTHMONT
WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ___ Other ✓ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1	L 4%	0-8	SBK / C	1:1/MIX/FI	5	S	PS	S	0.2
		8-48	WABK / C	1:1/MIX/FI/SS/SP					
2	L 5%	0-10	SBK / C	1:1/MIX/FI	5	S	PS	S	0.2
		10-48	WABK / C	1:1/FI/SS/SP					
3									
4									
5									

AVAILABLE SPACE (.1945): BM FIELD SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: 0.20 GAD/SF
EVALUATED BY: S. HEDRICK OTHER(S) PRESENT: JACK HINES
COMMENTS: SYSTEM INSTALLED PRIMARILY ON LOT # 105 APPROACHING LOT LINE W/ #106

000667