DEPARTMENT OF ENVIRONMENT,
HEALTH & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

DRAFT

SHEET____ OF____

PROPERTY I.D.#:____

DATE:____

COUNTY:____

SOIL SITE EVALUATION FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: C.P. Madison
OWNER__AGENT:__PHONE:____
ADDRESS:____
APPLICATION DATE:____ DATE EVALUATED____
PROPOSED FACILITY:____
PROPERTY SIZE:____
LOCATION OF SITE: Lot 34 Canterbury
WATER SUPPLY: On-site Well____ Comm. Well____ Public____ Other____ EVAL. METHOD: Auger Boring____ Pit ✓ Cut____

PROFILE #	.1940 LANDSCP POS./ SLOPE(%)	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY	MATRIX COLOR	MOTTLE COLOR	OTHER PROFILE FACTORS
1	linear	0 to 6"	L	GR				.1942 Wetness Cond. - N/A
		6 to 36	C	3GK	1:1			.1943 Depth/.1956 Sapr. - N/A
		36 to 48	CL	weak 3GK	1:1			.1944 Restrictive Hori. - N/A
								.1948 Profile Class. - PS
								Profile LTAR - .25
2	linear	0 to 7"	L	GR				.1942 Wetness Cond. - N/A
		~~7 to 36~~	~~C~~					.1943 Depth/.1956 Sapr. - 18"
		7 to 18	C	3GK	1:1			.1944 Restrictive Hori. - N/A
		18 to 48	Saprolite Loamy Sand					.1948 Profile Class. - PS
								Profile LTAR - .4
3	linear	0 to 7	L	GR				.1942 Wetness Cond. - N/A
		7 to 18	C	3GK	1:1			.1943 Depth/.1956 Sapr. - 18"
		18 to 48	Saprolite Sandy loam					.1944 Restrictive Hori. - N/A
								.1948 Profile Class. - PS
								Profile LTAR - .4
4								.1942 Wetness Cond. -
								.1943 Depth/.1956 Sapr. -
								.1944 Restrictive Hori. -
								.1948 Profile Class. -
								Profile LTAR -

AVAILABLE SPACE (.1945) Yes OTHER FACTORS (.1946)____ SITECLASSIFICATION (.1948) PS

SYSTEM TYPE____ LONG-TERMACCEPTANCE RATE(S) .3

EVALUATED BY: L.C. Moore OTHER(S) PRESENT: Dick Crandil

COMMENTS:____

0001277