HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: 6K22-A-29
PROPERTY RECORDED:
COUNTY: IREDELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: C. DOUGLAS MADISON OWNER: AGENT: ✓ PHONE: 873-0521
ADDRESS: 1805 SARRIET RD APPLICATION DATE: 10/20/94 DATE EVALUATED: 10/20/94
STVL, NC 28677 PROPOSED FACILITY: 3BR HOUSE
PROPERTY SIZE: 106' x 190'
LOCATION OF SITE: #29 CANTERBURY II
WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY		
1	N 4%	0-20	C	ABK	1:1 / FI	.1942 WETNES CONDITION	S
		20-48	SiC	WABK	1:1 FR/SP	.1943/.1956 SAPROLITE	S
						.1944 RESTRICTIVE HORIZON	S
						.1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	0.35 GPD/FT2
2	N 6%	0-15	C	ABK	1:1 / FI	.1942 WETNES CONDITION	S
		15-48	SiC	WABK	1:1 / FR/SP	.1943/.1956 SAPROLITE	PS
		SiC/SAPROLITE AT 36"				.1944 RESTRICTIVE HORIZON	S
						.1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	0.33 GPD/FT2
3	L 8%	0-48	SiC	WABK	1:1 / FR/SP	.1942 WETNESS CONDITION	S
		SiC MIX	SAPROLITE	AT 38"		.1943/.1956 SAPROLITE	PS
						.1944 RESTRICTIVE HORIZON	S
						.1948 PROFILE CLASSIFICATION	S
						PROFILE LTAR	0.33 GPD/FT2
4						.1942 WETNESS CONDITION	-
						.1943/.1956 SAPROLITE	-
						.1944 RESTRICTIVE HORIZON	-
						.1948 PROFILE CLASSIFICATION	-
						PROFILE LTAR	-
5						.1942 WETNESS CONDITION	-
						.1943/.1956 SAPROLITE	-
						.1944 RESTRICTIVE HORIZON	-
						.1948 PROFILE CLASSIFICATION	-
						PROFILE LTAR	-

AVAILABLE SPACE (.1945) S SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: 0.33 GPD/FT2
OTHER FACTORS(.1946) NONE SYSTEM TYPE CONV. GRAVITY
EVALUATED BY: S. HEDRICK OTHER(S) PRESENT: TERRY O'BRIEN, DICK CRANDALL, RL CHRISTY
COMMENTS:

DRAFT