DEPARTMENT OF ENVIRONMENT,
HEALTH & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

DRAFT

SHEET____ OF____

PROPERTY I.D.#:_____
DATE:_____
COUNTY:_____

SOIL SITE EVALUATION FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: C. Douglas madison
ADDRESS:_____
OWNER___AGENT:___PHONE:_____
APPLICATION DATE:_____ DATE EVALUATED_____
PROPOSED FACILITY:_____
PROPERTY SIZE:_____
LOCATION OF SITE: Lot 27 Canterbury Sec II
WATER SUPPLY: On-site Well____ Comm. Well___ Public___ Other____ EVAL. METHOD: Auger Boring___ Pit___ Cut___

PROFILE #	.1940 LANDSCP POS./ SLOPE(%)	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY	MATRIX COLOR	MOTTLE COLOR	OTHER PROFILE FACTORS
1	linear 10%	0 to 6	L	GR				.1942 Wetness Cond. - N/A
		6 to 30	C	SBK	I:I			.1943 Depth/.1956 Sapr. - N/A
		30 to 48	CL	weak SBK	I:I			.1944 Restrictive Hori. - N/A
								.1948 Profile Class. - PS
								Profile LTAR - .3
2	linear 10%	0 to 6	L	GR				.1942 Wetness Cond. - N/A
		6 to 30	C	SBK	I:I			.1943 Depth/.1956 Sapr. - N/A
		30 to 48	CL	weak SBK	I:I			.1944 Restrictive Hori. - N/A
								.1948 Profile Class. - PS
								Profile LTAR - .3
3	linear 10%	0 to 6	L	GR				.1942 Wetness Cond. - N/A
		6 to 24	C	SBK	I:I			.1943 Depth/.1956 Sapr. - N/A
		24 to 36	CL	weak SBK	I:I			.1944 Restrictive Hori. - N/A
		36 to 48	BK	Sandy loam				.1948 Profile Class. - PS
								Profile LTAR - .3
4								.1942 Wetness Cond. -
								.1943 Depth/.1956 Sapr. -
								.1944 Restrictive Hori. -
								.1948 Profile Class. -
								Profile LTAR -

AVAILABLE SPACE (.1945) yes OTHER FACTORS (.1946)_____ SITECLASSIFICATION (.1948) PS

SYSTEM TYPE [redacted] LONG-TERMACCEPTANCE RATE(S) .3

EVALUATED BY: J.C. Moore OTHER(S) PRESENT: Rick Crandell

COMMENTS:_____

0012 92