HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: GM-A-16-(41)
PROPERTY RECORDED:
COUNTY: IREDELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: C. D. MADISON OWNER: AGENT ✓ PHONE: 873-0521
ADDRESS: 1805 SAFRIT RD APPLICATION DATE: 3/11/99 DATE EVALUATED: 3/11/99
STATESVILLE, NC 28677 PROPOSED FACILITY: 3BR HOUSE
PROPERTY SIZE: SITE IS LIMITED
LOCATION OF SITE: CANTERBURY #41
WATER SUPPLY: On-Site Well___ Comm. Well___ Public___ Other___ EVAL. METHOD: Auger Boring___ Pit___ Cut___

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	(a)(2) STRUCTURE	(a)(3) MINEROLOGY	
1	L 4%	0-6	SCL	GR	1:1 / FR	.1942 WETNES CONDITION S
		6-48	C	ABK	1:1 / FI	.1943/.1956 SAPROLITE S
						.1944 RESTRICTIVE HORIZON S
						.1948 PROFILE CLASSIFICATION PS
						PROFILE LTAR 0.3
2	L 4%	0-8	SCL	GR	1:1 / FR	.1942 WETNES CONDITION S
		8-48	C	ABK	1:1 / FI	.1943/.1956 SAPROLITE S
						.1944 RESTRICTIVE HORIZON S
						.1948 PROFILE CLASSIFICATION PS
						PROFILE LTAR 0.3
3	L 4%	0-2	SCL	GR	1:1 / FR	.1942 WETNESS CONDITION S
		2-48	C	ABK	1:1 / FI	.1943/.1956 SAPROLITE S
						.1944 RESTRICTIVE HORIZON S
						.1948 PROFILE CLASSIFICATION PS
						PROFILE LTAR 0.3
4						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -
5						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -

AVAILABLE SPACE (.1945) S SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: 0.30 GPD/FT
OTHER FACTORS(.1946) NONE SYSTEM TYPE CONV. GRAVITY
EVALUATED BY: S. HEDRICK OTHER(S) PRESENT: DICK CRAMPTON, TERRY O'BRIEN, JOE?
COMMENTS: AREA USED AS LOGGING PATH & COMPACTED SOIL IN MOST OF SEPTIC AREA

DRAFT