HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: 6M-A-16(8)
PROPERTY RECORDED:
COUNTY: IREDELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: C.D. MADISON OWNER: ✓ AGENT: PHONE: 873-0521
ADDRESS: 1807 SAFRIET DR APPLICATION DATE: 4/8/94 DATE EVALUATED: 4/12/94
STVL, NC 28677 PROPOSED FACILITY: 3BR HOUSE
PROPERTY SIZE: 100' X 150'
LOCATION OF SITE: # 8 CANTERBURY
WATER SUPPLY: On-Site Well___ Comm. Well___ Public ✓ Other___ EVAL. METHOD: Auger Boring ✓ Pit___ Cut___

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY		
1	N 6%	0-48	C	WABK	1:1 / FI	.1942 WETNES CONDITION	5
						.1943/.1956 SAPROLITE	5
						.1944 RESTRICTIVE HORIZON	5
						.1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	0.33 GPD/FT²
2	N 4%	0-48	C	W ABK	1:1 / FI	.1942 WETNES CONDITION	5
						.1943/.1956 SAPROLITE	5
						.1944 RESTRICTIVE HORIZON	5
						.1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	0.33 GPD/FT²
3						.1942 WETNESS CONDITION	
						.1943/.1956 SAPROLITE	
						.1944 RESTRICTIVE HORIZON	
						.1948 PROFILE CLASSIFICATION	
						PROFILE LTAR	
4						.1942 WETNESS CONDITION	
						.1943/.1956 SAPROLITE	
						.1944 RESTRICTIVE HORIZON	
						.1948 PROFILE CLASSIFICATION	
						PROFILE LTAR	
5						.1942 WETNESS CONDITION	
						.1943/.1956 SAPROLITE	
						.1944 RESTRICTIVE HORIZON	
						.1948 PROFILE CLASSIFICATION	
						PROFILE LTAR	

AVAILABLE SPACE (.1945) 5 SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE:
OTHER FACTORS(.1946) NONE SYSTEM TYPE CONV. GRAVITY // ABBPS REPAIR
EVALUATED BY: STEVE HENDRICK OTHER(S) PRESENT: TERRY O'BRIEN
COMMENTS:

DRAFT