HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: 6M-A-16 (9)
PROPERTY RECORDED:
COUNTY: IREDELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: C. D MADISON OWNER: ✓ AGENT: PHONE: 873-0521
ADDRESS: 1805 SAFRIET DR APPLICATION DATE: 4/8/94 DATE EVALUATED: 4/12/94
SNL, NC 28677 PROPOSED FACILITY: 3 BR HOUSE
PROPERTY SIZE: 100 x 150'
LOCATION OF SITE: #9 CANTERBURY
WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ___ Other ✓ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY		
1	N 4%	0-4	CL	GR	1:1 / VFR	.1942 WETNES CONDITION	S
		4-32	C	SBK	1:1 / FI	.1943/.1956 SAPROLITE	S
		32-48	SiC	CR	1:1 / FR	.1944 RESTRICTIVE HORIZON	S
						.1945 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	0.35
2	N 4%	0-4	CL	GR	1:1 / VFR	.1942 WETNES CONDITION	S
		4-32	C	SBK	1:1 / FI	.1943/.1956 SAPROLITE	S
		32-48	SiC	CR	1:1 / FR	.1944 RESTRICTIVE HORIZON	S
						.1945 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	0.35
3	L 6%	0-5	CL	GR	1:1 / VFR	.1942 WETNESS CONDITION	S
		5-32	C	SBK	1:1 / FI	.1943/.1956 SAPROLITE	S
		32-48	SiC	CR	1:1 / FR	.1944 RESTRICTIVE HORIZON	S
						.1945 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	0,35
4						.1942 WETNESS CONDITION	-
						.1943/.1956 SAPROLITE	-
						.1944 RESTRICTIVE HORIZON	-
						.1945 PROFILE CLASSIFICATION	-
						PROFILE LTAR	-
5						.1942 WETNESS CONDITION	-
						.1943/.1956 SAPROLITE	-
						.1944 RESTRICTIVE HORIZON	-
						.1945 PROFILE CLASSIFICATION	-
						PROFILE LTAR	-

AVAILABLE SPACE (.1945): S SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: 0.35 GPD/FT²
OTHER FACTORS(.1946): NONE SYSTEM TYPE: CONV. GRAVITY / PPBPS REPAIR
EVALUATED BY: S. HEDRICK OTHER(S) PRESENT: TERRY O'BRIEN
COMMENTS:

DRAFT