HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: 6M-A-16 (Pt.
PROPERTY RECORDED:
COUNTY: IREDELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: C. O. MADISON OWNER: AGENT: ✓ PHONE: 873-0521
ADDRESS: 1805 SAFRIET RD APPLICATION DATE: 3/11/99 DATE EVALUATED: 3/19/99
STL, NC 28677 PROPOSED FACILITY: 3BR HOUSE
PROPERTY SIZE:
LOCATION OF SITE: CANTERBURY #5
WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ✓ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY		
1	L 2%	0-4	CL	GR	1:1 / FR	.1942 WETNES CONDITION	S
		4-48	C	ABK	1:1 / FI	.1943/.1956 SAPROLITE	S
						.1944 RESTRICTIVE HORIZON	S
						.1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	0.3
2	L 3%	0-3	SCL	GR	1:1 / FR	.1942 WETNES CONDITION	S
		3-48	C	ABK	1:1 / FI	1943/.1956 SAPROLITE	S
						.1944 RESTRICTIVE HORIZON	S
						.1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	0.3
3	L 4%	0-2	SCL	GR	1:1 / FR	.1942 WETNESS CONDITION	S
		2-48	C	ABK	1:1 / FI	.1943/.1956 SAPROLITE	S
						.1944 RESTRICTIVE HORIZON	S
						.1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	0.3
4						.1942 WETNESS CONDITION	-
						.1943/.1956 SAPROLITE	-
						.1944 RESTRICTIVE HORIZON	-
						.1948 PROFILE CLASSIFICATION	-
						PROFILE LTAR	-
5						.1942 WETNESS CONDITION	-
						.1943/.1956 SAPROLITE	-
						.1944 RESTRICTIVE HORIZON	-
						.1948 PROFILE CLASSIFICATION	-
						PROFILE LTAR	-

AVAILABLE SPACE (.1945) S SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: 0.30 gpd/ft²
OTHER FACTORS(.1946) NONE SYSTEM TYPE CONV. GRAVITY
EVALUATED BY: S. HEDRICK OTHER(S) PRESENT: DICK CRANDALL, TERRY O'BRIEN
COMMENTS:

DRAFT